



SECTION 11 ANNUAL REPORT

| | |
|---------------------------------|-------------------------------------|
| Drinking-Water System Number: | 210000194 |
| Drinking-Water System Name: | Minden Hills DWS |
| Drinking-Water System Owner: | Township of Minden Hills |
| Drinking-Water System Category: | Large Municipal Residential |
| Period being reported: | January 1, 2015 – December 31, 2015 |

| | |
|--|---|
| <p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [] No [X]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [x] No []</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px; text-align: center;"> <p>7 Milne Street Minden, Ontario K0M 2K0</p> </div> | <p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 50px;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [] No [X]</p> <p>Number of Interested Authorities you report to: <input style="width: 50px;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [] No [X]</p> |
|--|---|

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

| Drinking Water System Name | Drinking Water System Number |
|----------------------------|------------------------------|
| Not Applicable | |

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [] No [X]



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method

Describe your Drinking-Water System

The Minden Well Supply drinking water system consists of a disinfection system that uses liquid sodium hypochlorite injected into the raw water. Continuous monitoring for free chlorine residual and turbidity is carried out prior to the treated water entering the distribution system. Iron and manganese sequestering is accomplished using sodium silicate. Raw flow rate is monitored on both wells using magnetic flow meters. Well two is for standby use only and is exercised weekly to refresh water quality and obtain regulatory samples. A 1500 cubic meter elevated water tower provides storage and augments pressure to the distribution. A backup generator is located at the pumphouse.

List all water treatment chemicals used over this reporting period

Sodium hypochlorite
Sodium silicate

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Please provide a brief description and a breakdown of monetary expenses incurred

n/a

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|---------------|---------------------------------|--------|-----------------|--|------------------------|
| 2015/02/03 | Chlorine | 0.06 | mg/L | Well pumps locked out, flushed contact pipe, restored chlorine residual. | 2015/02/03 |
| 2015/02/03 | Chlorine | 0.04 | mg/L | Well pumps locked out, flushed contact pipe, repaired chlorine pumps, restored chlorine residual. | 2015/02/03 |
| 2015/03/05 | Chlorine | 0.18 | mg/L | Well pumps locked out, flushed contact pipe, repaired chlorine pump, restored chlorine residual. | 2015/03/05 |
| 2015/07/01 | Total Coliforms in distribution | 4 | cfu/100 mL | Flushed distribution system, resampled. | 2015/07/06 |
| 2015/12/14 | Chlorine | 0.03 | mg/L | Well pumps locked out, flushed contact pipe, relieve air lock in chemical pump, restored chlorine residual. | 2015/12/14 |
| 2015/12/21 | Chlorine | 0.03 | mg/L | Well pumps locked out, flushed contact pipe, repaired chemical pump, restored chlorine residual. | 2015/12/21 |
| 2015/12/30 | Chlorine | 0.08 | mg/L | Well pumps locked out, flushed contact pipe, repaired chemical pump, restored chlorine residual, sampled distribution water. | 2016/01/04 |

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

| Location | Number of Samples | Range of E.Coli or Fecal Results (min)-(max) | Range of Total Coliform Results (min)-(max) | Number of HPC Samples | Range of HPC Results (min)-(max) |
|-------------------|-------------------|--|---|-----------------------|----------------------------------|
| Raw - RW1 | 52 | 0 - 0 | 0 - 0 | 0 | - |
| Raw - RW2 | 52 | 0 - 0 | 0 - 0 | 0 | - |
| Treated - TW | 54 | 0 - 0 | 0 - 0 | 54 | 0 - 4 |
| Distribution - DW | 160 | 0 - 0 | 0 - 4 | 160 | 0 - 32 |

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| | Number of Grab Samples | Range of Results (min)-(max) |
|---|------------------------|------------------------------|
| Turbidity Well 1 | 13 | 0.11-0.21 NTU |
| Turbidity Well 2 | 13 | 0.23-0.29 NTU |
| Chlorine (Free) – Treated Water | 8760 | 0.00-4.85 mg/L |
| Chlorine (Free) - Distribution | 7/week minimum | 0.50-2.04 mg/L |
| Fluoride (If DWS provides fluoridation) | N/A | |

NOTE: For continuous monitors use 8760 as the number of samples.

NOTE: Record the unit of measure if it is **not** milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

| Date of legal instrument issued | Parameter | Date Sampled | Result | Unit of Measure |
|---------------------------------|------------|--------------|--------|-----------------|
| Reg. 170/03, SDWA 2002 | Alkalinity | 2015/04/09 | 151 | mg/L |
| | | 2015/04/09 | 147 | |
| | | 2015/09/28 | 143 | |
| | | 2015/09/28 | 144 | |

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value | Exceedance |
|---|---|---|------------|
| See attached Annual Summary – Schedule 23 and Additional Inorganics | 2014/01/20 2015 (quarterly nitrite & nitrate) 2013/01/02 F & Na | See attached Annual Summary – Schedule 23 and Additional Inorganics | No |

Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

| Location Type | Number of Samples | Range of Lead Results (ug/L) (min)–(max) | Number of Exceedances |
|---------------|-------------------|--|-----------------------|
| Plumbing | n/a | | |
| Distribution | n/a | | |

Summary of Organic parameters sampled during this reporting period or the most recent sample results

| Parameter | Sample Date | Result Value | Exceedance |
|---|--------------------------|---|------------|
| See attached Annual Summary – Schedule 24 | 2014/01/13 2014/01/20 | See attached Annual Summary – Schedule 24 | No |
| THM - (ug/L) | 2015 quarterly | Range 5.8 – 26 Running average 17 | No |

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

| Parameter | Result Value | Unit of Measure | Date of Sample |
|-----------|--------------|-----------------|----------------|
| N/A | | | |

The Ontario Clean Water Agency aims to strictly adhere to operational and compliance limits, however certain operational circumstances may cause results to be temporarily outside of the limits. Limits that are momentarily surpassed as a result of pump start-ups, power outages/generator tests, pump rotation, calibrations, alarm verification, etc are a normal part of operations and do not indicate a true exceedance. A true exceedance will be noted and documented within the report.

Attachments

Ontario Clean Water Agency
Performance Assessment Report Water

From: 01/01/2015 to 31/12/2015

Facility: [5838] MINDEN DRINKING WATER SYSTEM

| | 01/2015 | 02/2015 | 03/2015 | 04/2015 | 05/2015 | 06/2015 | 07/2015 | 08/2015 | 09/2015 | 10/2015 | 11/2015 | 12/2015 | <-Total-> | <-Avg.-> | <-Max.-> | <-Min.-> | <-Criteria-> |
|---|----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|---------|---------|-----------|----------|----------|----------|--------------|
| Flows: | | | | | | | | | | | | | | | | | |
| Raw Flow: Monthly Total - Well1 (m³/d) | 10304.00 | 10076.00 | 11457.00 | 10201.00 | 11626.00 | 11446.00 | 13393.00 | 13359.38 | 12350.00 | 10770.00 | 9953.00 | 9848.41 | 134983.79 | | | | |
| Raw Flow: Monthly Total - Well2 (m³/d) | 26.13 | 26.74 | 24.79 | 21.46 | 27.26 | 19.74 | 19.39 | 32.69 | 20.44 | 25.00 | 33.00 | 23.52 | 300.16 | | | | |
| Raw Flow: Monthly Avg - Well1 (m³/d) | 332.39 | 359.86 | 369.58 | 340.03 | 381.48 | 381.53 | 432.03 | 430.95 | 411.67 | 347.42 | 331.77 | 317.69 | | 369.70 | | | |
| Raw Flow: Monthly Avg - Well2 (m³/d) | 0.84 | 0.96 | 0.80 | 0.72 | 0.88 | 0.66 | 0.63 | 1.05 | 0.68 | 0.81 | 1.10 | 0.76 | | 0.82 | | | |
| Raw Flow: Monthly Max - Well1 (m³/d) | 464.00 | 492.00 | 432.00 | 439.00 | 723.00 | 487.00 | 540.00 | 650.00 | 538.00 | 437.00 | 535.00 | 424.00 | | | 723.00 | | 1970.00 |
| Raw Flow: Monthly Max - Well2 (m³/d) | 9.64 | 9.58 | 5.81 | 5.90 | 8.35 | 6.11 | 8.02 | 8.05 | 5.94 | 7.00 | 10.00 | 8.00 | | | 10.00 | | 657.00 |
| Turbidity: | | | | | | | | | | | | | | | | | |
| Raw: Max Turbidity - Well1 (NTU) | 0.18 | 0.18 | 0.21 | 0.18 | 0.20 | 0.19 | 0.19 | 0.19 | 0.18 | 0.18 | 0.19 | 0.18 | | | 0.21 | | |
| Raw: Max Turbidity - Well2 (NTU) | 0.24 | 0.24 | 0.26 | 0.26 | 0.24 | 0.26 | 0.25 | 0.29 | 0.23 | 0.24 | 0.24 | 0.24 | | | 0.29 | | |
| Chemical Parameters: | | | | | | | | | | | | | | | | | |
| Treated: Max Nitrite - TW (mg/L) | < 0.003 | | | < 0.003 | | | < 0.003 | | | < 0.003 | | | | | < 0.003 | | 1 |
| Treated: Max Nitrate - TW (mg/L) | < 0.006 | | | < 0.006 | | | < 0.006 | | | < 0.006 | | | | | < 0.006 | | 10 |
| Distribution: Max THM - DW (µg/l) | 14 | | | 5.8 | | | 26 | | | 21 | | | | 16.7 | 26 | | 100 |
| Chlorine Residuals: | | | | | | | | | | | | | | | | | |
| Treated: Min Free Cl2 Resid - TW (mg/L) | 0.04 | 0.04 | 0.17 | 0.00 | 0.74 | 0.33 | 0.43 | 0.88 | 0.94 | 0.78 | 0.73 | 0.00 | | | | 0.00 | 0.26 |
| Treated: Max Free Cl2 Resid - TW (mg/L) | 2.00 | 2.00 | 2.00 | 2.00 | 2.00 | 4.57 | 4.85 | 3.92 | 3.76 | 3.45 | 3.57 | 3.89 | | | 4.85 | | |
| Dist: Min Free Cl2 Resid - DW (mg/L) | 1.07 | 1.02 | 1.04 | 1.01 | 1.15 | 1.11 | 0.50 | 0.60 | 0.93 | 0.58 | 0.74 | 0.71 | | | | 0.50 | 0.05 |
| Dist: Max Free Cl2 Resid - DW (mg/L) | 1.82 | 1.82 | 1.87 | 1.95 | 2.04 | 1.86 | 1.67 | 1.79 | 1.74 | 1.62 | 1.77 | 1.77 | | | 2.04 | | |
| Bactl Samples Collected: | | | | | | | | | | | | | | | | | |
| Raw Bactl: # of samples - Well1 | 4 | 4 | 5 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 52 | | | | |
| Raw Bactl: # of samples - Well2 | 4 | 4 | 5 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 52 | | | | |
| Treated Bactl: # of samples - TW | 4 | 4 | 5 | 4 | 4 | 5 | 5 | 5 | 4 | 4 | 5 | 5 | 54 | | | | |
| Dist Bactl: # of samples - DW | 12 | 12 | 15 | 12 | 12 | 15 | 15 | 15 | 12 | 12 | 15 | 13 | 160 | | | | |
| Treated Bactl: # of TC exceedances - TW | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | | |
| Treated Bactl: # of EC exceedances - TW | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | | 0 |
| Dist Bactl: # of TC exceedances - DW | 0 | 0 | 0 | 0 | 0 | 0 | 1 | 0 | 0 | 0 | 0 | 0 | 1 | | | | 0 |
| Dist Bactl: # of EC exceedances - DW | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | | | | 0 |

Schedule 23 and Additional Inorganics

Drinking-Water System Number: 210000194
 Drinking-Water System Name: MINDEN DRINKING WATER SYSTEM
 Drinking-Water System Owner: Title Holder: Municipality
 Drinking-Water System Category: Large Municipal Residential
 Period being reported: 01/2015 12/2015

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

| TREATED WATER | Sample Date (mm/dd/yyyy) | Sample Result | MAC | No. of Exceedances | |
|------------------------------|-----------------------------|---------------|--------|--------------------|---------|
| | | | | MAC | 1/2 MAC |
| Antimony: Sb (ug/L) - TW | 1/20/2014 | < 0.02 | 6.0 | No | No |
| Arsenic: As (ug/L) - TW | 1/20/2014 | < 0.2 | 25.0 | No | No |
| Barium: Ba (ug/L) - TW | 1/20/2014 | 148 | 1000.0 | No | No |
| Boron: B (ug/L) - TW | 1/20/2014 | 28 | 5000.0 | No | No |
| Cadmium: Cd (ug/L) - TW | 1/20/2014 | 0.007 | 5.0 | No | No |
| Chromium: Cr (ug/L) - TW | 1/20/2014 | 1.5 | 50.0 | No | No |
| Mercury: Hg (ug/L) - TW | 1/20/2014 | < 0.01 | 1.0 | No | No |
| Selenium: Se (ug/L) - TW | 1/20/2014 | < 1.0 | 10.0 | No | No |
| Uranium: U (ug/L) - TW | 1/20/2014 | 0.93 | 20.0 | No | No |
| Additional Inorganics | | | | | |
| Fluoride (mg/L) - TW | 1/2/2013 | 0.2 | 1.5 | No | No |
| Nitrite (mg/L) - TW | 1/13/2015 | < 0.003 | 1.0 | No | No |
| Nitrite (mg/L) - TW | 4/13/2015 | < 0.003 | 1.0 | No | No |
| Nitrite (mg/L) - TW | 7/16/2015 | < 0.003 | 1.0 | No | No |
| Nitrite (mg/L) - TW | 10/27/2015 | < 0.003 | 1.0 | No | No |
| Nitrate (mg/L) - TW | 1/13/2015 | < 0.006 | 10.0 | No | No |
| Nitrate (mg/L) - TW | 4/13/2015 | < 0.006 | 10.0 | No | No |
| Nitrate (mg/L) - TW | 7/16/2015 | < 0.006 | 10.0 | No | No |
| Nitrate (mg/L) - TW | 10/27/2015 | < 0.006 | 10.0 | No | No |
| Sodium: Na (mg/L) - TW | 1/2/2013 | 16.3 | 20* | No | Yes |

*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified mg/L when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.

Schedule 24

Drinking-Water System Number: 210000194
 Drinking-Water System Name: MINDEN DRINKING WATER SYSTEM
 Drinking-Water System Owner: Title Holder: Municipality
 Drinking-Water System Category: Large Municipal Residential
 Period being reported: 01/2015 12/2015

Summary of Organic parameters sampled during this reporting period or the most recent sample results

| | Sample Date (mm/dd/yyyy) | Sample Result | MAC | Number of Exceedances | |
|---|-----------------------------|---------------|--------|-----------------------|---------|
| | | | | MAC | 1/2 MAC |
| TREATED WATER | | | | | |
| Alachlor (ug/L) - TW | 1/13/2014 | < 0.02 | 5.00 | No | No |
| Aldicarb (ug/L) - TW | 1/13/2014 | < 0.01 | 9.00 | No | No |
| Aldrin+Dieldrin (ug/L) - TW | 1/13/2014 | < 0.01 | 0.70 | No | No |
| Atrazine + N-dealkylated metabolites (ug/L) - TW | 1/13/2014 | < 0.01 | 5.00 | No | No |
| Azinphos-methyl (ug/L) - TW | 1/13/2014 | < 0.02 | 20.00 | No | No |
| Bendiocarb (ug/L) - TW | 1/13/2014 | < 0.01 | 40.00 | No | No |
| Benzene (ug/L) - TW | 1/20/2014 | < 0.32 | 5.00 | No | No |
| Benzo(a)pyrene (ug/L) - TW | 1/13/2014 | < 0.004 | 0.01 | No | No |
| Bromoxynil (ug/L) - TW | 1/13/2014 | < 0.33 | 5.00 | No | No |
| Carbaryl (ug/L) - TW | 1/13/2014 | < 0.01 | 90.00 | No | No |
| Carbofuran (ug/L) - TW | 1/13/2014 | < 0.01 | 90.00 | No | No |
| Carbon Tetrachloride (ug/L) - TW | 1/20/2014 | < 0.16 | 5.00 | No | No |
| Chlordane: Total (ug/L) - TW | 1/13/2014 | < 0.01 | 7.00 | No | No |
| Chlorpyrifos (ug/L) - TW | 1/13/2014 | < 0.02 | 90.00 | No | No |
| Cyanazine (ug/L) - TW | 1/13/2014 | < 0.03 | 10.00 | No | No |
| Diazinon (ug/L) - TW | 1/13/2014 | < 0.02 | 20.00 | No | No |
| Dicamba (ug/L) - TW | 1/13/2014 | < 0.2 | 120.00 | No | No |
| 1,2-Dichlorobenzene (ug/L) - TW | 1/20/2014 | < 0.41 | 200.00 | No | No |
| 1,4-Dichlorobenzene (ug/L) - TW | 1/20/2014 | < 0.36 | 5.00 | No | No |
| DDT + metabolites (ug/L) - TW | 1/13/2014 | < 0.01 | 30.00 | No | No |
| 1,2-Dichloroethane (ug/L) - TW | 1/20/2014 | < 0.35 | 5.00 | No | No |
| 1,1-Dichloroethylene (ug/L) - TW | 1/20/2014 | < 0.33 | 14.00 | No | No |
| Dichloromethane (Methylene Chloride) (ug/L) - TW | 1/20/2014 | < 0.35 | 50.00 | No | No |
| 2,4-Dichlorophenol (ug/L) - TW | 1/13/2014 | < 0.15 | 900.00 | No | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) (ug/L) - TW | 1/13/2014 | < 0.19 | 100.00 | No | No |
| Diclofop-methyl (ug/L) - TW | 1/13/2014 | < 0.4 | 9.00 | No | No |
| Dimethoate (ug/L) - TW | 1/13/2014 | < 0.03 | 20.00 | No | No |
| Dinoseb (ug/L) - TW | 1/13/2014 | < 0.36 | 10.00 | No | No |
| Diquat (ug/L) - TW | 1/20/2014 | < 1.0 | 70.00 | No | No |
| Diuron (ug/L) - TW | 1/13/2014 | < 0.03 | 150.00 | No | No |
| Glyphosate (ug/L) - TW | 1/20/2014 | < 1.0 | 280.00 | No | No |
| Heptachlor+hepachlor epoxide (ug/L) - TW | 1/13/2014 | < 0.01 | 3.00 | No | No |
| Lindane (ug/L) - TW | 1/13/2014 | < 0.01 | 4.00 | No | No |
| Malathion (ug/L) - TW | 1/13/2014 | < 0.02 | 190.00 | No | No |
| Methoxychlor (ug/L) - TW | 1/13/2014 | < 0.01 | 900.00 | No | No |
| Metolachlor (ug/L) - TW | 1/13/2014 | < 0.01 | 50.00 | No | No |
| Metribuzin (ug/L) - TW | 1/13/2014 | < 0.02 | 80.00 | No | No |
| Monochlorobenzene (Chlorobenzene) (ug/L) - TW | 1/20/2014 | < 0.3 | 80.00 | No | No |
| Paraquat (ug/L) - TW | 1/20/2014 | < 1.0 | 10.00 | No | No |
| Parathion (ug/L) - TW | 1/13/2014 | < 0.02 | 50.00 | No | No |
| PCB (ug/L) - TW | 1/13/2014 | < 0.04 | 3.00 | No | No |
| Pentachlorophenol (ug/L) - TW | 1/13/2014 | < 0.15 | 60.00 | No | No |
| Phorate (ug/L) - TW | 1/13/2014 | < 0.01 | 2.00 | No | No |
| Picloram (ug/L) - TW | 1/13/2014 | < 1.0 | 190.00 | No | No |
| Prometryne (ug/L) - TW | 1/13/2014 | < 0.03 | 1.00 | No | No |
| Simazine (ug/L) - TW | 1/13/2014 | < 0.01 | 10.00 | No | No |
| Temephos (ug/L) - TW | 1/13/2014 | < 0.01 | 280.00 | No | No |
| Terbufos (ug/L) - TW | 1/13/2014 | < 0.01 | 1.00 | No | No |
| Tetrachloroethylene (ug/L) - TW | 1/20/2014 | < 0.35 | 30.00 | No | No |
| 2,3,4,6-Tetrachlorophenol (ug/L) - TW | 1/13/2014 | < 0.14 | 100.00 | No | No |
| Triallate (ug/L) - TW | 1/13/2014 | < 0.01 | 230.00 | No | No |
| Trichloroethylene (ug/L) - TW | 1/20/2014 | < 0.44 | 50.00 | No | No |
| 2,4,6-Trichlorophenol (ug/L) - TW | 1/13/2014 | < 0.25 | 5.00 | No | No |
| 2,4,5-T (ug/L) - TW | 1/13/2014 | < 0.22 | 280.00 | No | No |
| Trifluralin (ug/L) - TW | 1/13/2014 | < 0.02 | 45.00 | No | No |
| Vinyl Chloride (ug/L) - TW | 1/20/2014 | < 0.17 | 2.00 | No | No |
| DISTRIBUTION WATER | | | | | |
| Trihalomethane: Total (ug/L) Annual Average - DW | 1/1/2015 | 16.7 | 100.00 | No | No |